

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Fältbuss – Del 4-19: Specifikation av protokoll i datalänksskiktet – Delar i fältbuss, Typ 19

*Industrial communication networks –
Fieldbus specifications –
Part 4-19: Data-link layer protocol specification –
Type 19 elements*

Som svensk standard gäller europastandarden EN 61158-4-19:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61158-4-19:2008.

Nationellt förord

Europastandarden EN 61158-4-19:2008

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61158-4-19, First edition, 2007 - Industrial communication networks - Fieldbus specifications - Part 4-19: Data-link layer protocol specification - Type 19 elements**

utarbetad inom International Electrotechnical Commission, IEC.

Denna standard, och de andra delarna i serien SS-EN 61158-4, ersätter SS-EN 61158-4, utgåva 1, 2004.

Tidigare fastställd svensk standard SS-EN 61158-4, utgåva 1, 2004, gäller ej fr o m 2011-02-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Industrial communication networks -
Fieldbus specifications -
Part 4-19: Data-link layer protocol specification -
Type 19 elements
(IEC 61158-4-19:2007)**

Réseaux de communication industriels -
Spécifications des bus de terrain -
Partie 4-19: Spécification des protocoles
des couches de liaison de données -
Éléments de type 19
(CEI 61158-4-19:2007)

Industrielle Kommunikationsnetze -
Feldbusse -
Teil 4-19: Protokollspezifikation des
Data Link Layer (Sicherheitsschicht) -
Typ 19-Elemente
(IEC 61158-4-19:2007)

This European Standard was approved by CENELEC on 2008-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 65C/474/FDIS, future edition 1 of IEC 61158-4-19, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61158-4-19 on 2008-02-01.

This and the other parts of the EN 61158-4 series supersede EN 61158-4:2004.

With respect to EN 61158-4:2004 the following changes were made:

- deletion of Type 6 fieldbus, and the placeholder for a Type 5 fieldbus data-link layer, for lack of market relevance;
- addition of new fieldbus types;
- partition into multiple parts numbered 4-1, 4-2, ..., 4-19.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2008-11-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-02-01

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the EN 61784 series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

IEC and CENELEC draw attention to the fact that it is claimed that compliance with this standard may involve the use of patents as follows, where the [xx] notation indicates the holder of the patent right:

Type 19 and possibly other types:

DE 102 37 097	[RI]	Korrektur von Signallaufzeiten in verteilten Kommunikationssystemen
DE 102 00 405 0416.4-42	[RI]	Verfahren zur Synchronisation in einem redundanten Kommunikationssystem
DE 102 00 502 4759.8-32	[RI]	Verfahren zur Laufzeitkorrektur in einer Kommunikationsstruktur
DE 102 00 4056364.0-31	[RI]	Verfahren zum Betreiben eines Netzwerks mit Ringtopologie
DE 103 12 907.3-31	[RI]	Kommunikationssystem mit redundanter Kommunikation

IEC and CENELEC take no position concerning the evidence, validity and scope of these patent rights.

The holders of these patent rights have assured IEC that they are willing to negotiate licences under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holders of these patent rights are registered with IEC. Information may be obtained from:

[RI] Rexroth Indramat GmbH
Bgm.-Dr.-Nebel-Str. 2
D - 97816 Lohr
Germany

Attention is drawn to the possibility that some of the elements of this standard may be the subject of patent rights other than those identified above. IEC and CENELEC shall not be held responsible for identifying any or all such patent rights.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61158-4-19:2007 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-3-19	NOTE Harmonized as EN 61158-3-19:2008 (not modified).
IEC 61158-5-16	NOTE Harmonized as EN 61158-5-16:2008 (not modified).
IEC 61158-5-19	NOTE Harmonized as EN 61158-5-19:2008 (not modified).
IEC 61158-6-16	NOTE Harmonized as EN 61158-6-16:2008 (not modified).
IEC 61158-6-19	NOTE Harmonized as EN 61158-6-19:2008 (not modified).
IEC 61784-2	NOTE Harmonized as EN 61784-2:2008 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-4-16	- ¹⁾	Industrial communication networks - Fieldbus specifications - Part 4-16: Data-link layer protocol specification - Type 16 elements	EN 61158-4-16	2008 ²⁾
IEC 61800-7-20x ³⁾	(all sub- parts)	Adjustable speed electrical power drive systems - Adjustable speed electrical power drive systems - Part 7-20x: Generic interface and use of profiles for power drive systems	EN 61800-7-20x	(all sub- parts)
ISO/IEC 7498-1	- ¹⁾	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	EN ISO/IEC 7498-1	1995 ²⁾
ISO/IEC 7498-3	- ¹⁾	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 8802-3	- ¹⁾	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

³⁾ At present, these subparts are IEC 61800-7-201, 7-202, 7-203 and 7-204.

CONTENTS

INTRODUCTION.....	8
1 Scope.....	9
1.1 General.....	9
1.2 Specifications.....	9
1.3 Procedures.....	9
1.4 Applicability.....	9
1.5 Conformance.....	9
2 Normative references	10
3 Terms, definitions, symbols, abbreviations and conventions	10
3.1 Reference model terms and definitions.....	10
3.2 Additional Type 19 terms and definitions	10
3.3 Symbols	13
3.4 Abbreviations	14
3.5 Additional conventions	15
4 DL-protocol overview.....	15
5 DLPDU structure	17
5.1 Overview	17
5.2 General DLPDU identification.....	17
5.3 General DLPDU structure.....	17
5.4 DLPDU header	18
5.5 MDT DLPDU	19
5.6 AT DLPDU	28
6 DL management	38
6.1 Overview.....	38
6.2 Enable and disable cyclic communication.....	38
6.3 Hot-plug procedure.....	43
6.4 Status procedures	44
7 Data transmission methods	44
7.1 Overview	44
7.2 SVC	45
7.3 RTC	45
8 Telegram timing and DLPDU handling	45
8.1 Usage of real-time channel with different network topologies.....	45
8.2 Communication mechanisms	46
8.3 Device synchronization.....	52
9 Error handling and monitoring	53
9.1 Failure of telegrams	53
9.2 Response to MDT and AT telegram failure	53
9.3 Service channel error messages.....	53
Annex A (Normative) – IDN – Identification numbers.....	55
A.1 IDN specification	55
A.2 Identification numbers in numerical orders	55
A.3 Detailed specification of communication-related IDNs	56
Bibliography.....	74

Figure 1 – Valid MDT and AT telegram combinations	16
Figure 2 – Offsets within MDT payload	23
Figure 3 – Offsets within AT payload	32
Figure 4 – Communication phase transitions	39
Figure 5 – Block diagram of master and slave	46
Figure 6 – Telegram sequence	48
Figure 7 – Beginning of telegram	49
Figure 8 – Access to the medium	50
Figure 9 – Timing diagram of CP0	52
Figure 10 – Timing diagram of CP1 and CP2	52
Figure 11 – Synchronization timing	53
Figure 12 – Synchronization signal generation	53
Figure A.1 – Lengths of MDTs (example)	61
Figure A.2 – Lengths of ATs (example)	63
Figure A.3 – Structure of MAC address	67
Figure A.4 – Structure of IP address	68
Figure A.5 – Structure of subnet mask	69
Figure A.6 – Structure of gateway address	70
Table 1 – Ethernet DLPDU identification	17
Table 2 – Data structure in a DLPDU	17
Table 3 – DLPDU payload header	18
Table 4 – DLPDU type	18
Table 5 – MDT MST header	19
Table 6 – MDT MST fields to be considered by the slave	19
Table 7 – MDT phase	19
Table 8 – MDT0 in CP0	20
Table 9 – MDT0 in CP1 and CP2	22
Table 10 – MDT1 in CP1 and CP2	22
Table 11 – MDT data field	23
Table 12 – MDT hot-plug field in HP0 and HP1	24
Table 13 – MDT hot-plug field in HP2	24
Table 14 – Device address field	24
Table 15 – HP control field (in HP0 and HP1)	25
Table 16 – MDT service channel field	26
Table 17 – MDT SVC (for each slave)	26
Table 18 – SVC control word (DLL)	27
Table 19 – MDT real-time data field	28
Table 20 – MDT real-time data (for each device)	28
Table 21 – Device control field	28
Table 22 – AT MST header	29
Table 23 – AT MST fields to be considered by the slave	29
Table 24 – AT0 structure in CP0	30

Table 25 – AT0 in CP1 and CP2	30
Table 26 – AT1 in CP1 and CP2	31
Table 27 – AT data field.....	31
Table 28 – AT hot-plug field in HP0 and HP1	32
Table 29 – AT hot-plug field in HP2	32
Table 30 – HP status field (in HP0 and HP1).....	33
Table 31 – AT service channel field	34
Table 32 – AT SVC (for each slave).....	34
Table 33 – AT SVC status description (DLL)	34
Table 34 – AT real-time data field	35
Table 35 – AT MS data field.....	36
Table 36 – AT MS data (for each device)	36
Table 37 – Device status field	36
Table 38 – CC data field	37
Table 39 – CC data field producer	37
Table 40 – CC consumer control.....	37
Table 41 – Synchronization classes of master and slave.....	49
Table 42 – Telegram transmission in RT and NR channels	51
Table A.1 – List of relevant communication-related IDNs	55
Table A.2 – Attributes of IDN S-0-1001	57
Table A.3 – Attributes of IDN S-0-1002	57
Table A.4 – Attributes of IDN S-0-1005	58
Table A.5 – Attributes of IDN S-0-1006	58
Table A.6 – Attributes for IDN S-0-1007	59
Table A.7 – Attributes for IDN S-0-1008	59
Table A.8 – Attributes of IDN S-0-1009	60
Table A.9 – RTC-Offset in MDT	60
Table A.10 – Attributes of IDN S-0-1010	61
Table A.11 – Attributes of IDN S-0-1011	61
Table A.12 – RTC Offset in AT.....	62
Table A.13 – Attributes of IDN S-0-1012	62
Table A.14 – Attributes of IDN S-0-1013	63
Table A.15 – RTC Offset in MDT.....	63
Table A.16 – Attributes of IDN S-0-1014	64
Table A.17 – RTC Offset in AT.....	64
Table A.18 – Attributes of IDN S-0-1015	65
Table A.19 – Attributes of IDN S-0-1016	65
Table A.20 – Attributes of IDN S-0-1017	66
Table A.21 – Attributes of IDN S-0-1018	66
Table A.22 – Attributes of IDN S-0-1019	67
Table A.23 – Attributes of IDN S-0-1020	68
Table A.24 – Attributes of IDN S-0-1021	68
Table A.25 – Attributes of IDN S-0-1022	69

Table A.26 – Attributes of IDN S-0-1023	70
Table A.27 – Structure of IDN S-0-1023 data	70
Table A.28 – Attributes of IDN S-0-1024	71
Table A.29 – Attributes of IDN S-0-1025	71
Table A.30 – Attributes of IDN S-0-1026	72
Table A.31 – Attributes of IDN S-0-1028	72
Table A.32 – Attributes of IDN S-0-1029	73
Table A.33 – Attributes of IDN S-0-1030	73

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 4-19: Data-link layer protocol specification – Type 19 elements

1 Scope

1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides communication opportunities to all participating data-link entities

- a) in a synchronously-starting cyclic manner, according to a pre-established schedule, and
- b) in a cyclic or acyclic asynchronous manner, as requested each cycle by each of those data-link entities.

Thus this protocol can be characterized as one which provides cyclic and acyclic access asynchronously but with a synchronous restart of each cycle.

1.2 Specifications

This standard specifies

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed data-link service provider;
- b) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.

1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI or fieldbus reference models, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

1.5 Conformance

This standard also specifies conformance requirements for systems implementing these procedures. This part of this standard does not contain tests to demonstrate compliance with such requirements.