

© Copyright SEK. Reproduction in any form without permission is prohibited.

## Industriell processstyrning – Fältbuss – **Del 4-4: Specifikation av protokoll i datalänksskiktet – Delar i fältbuss, Typ 4**

*Industrial communication networks –  
Fieldbus specifications –  
Part 4-4: Data-link layer protocol specification –  
Type 4 elements*

Som svensk standard gäller europastandarden EN 61158-4-4:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61158-4-4:2008.

### Nationellt förord

Europastandarden EN 61158-4-4:2008

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61158-4-4, First edition, 2007 - Industrial communication networks - Fieldbus specifications - Part 4-4: Data-link layer protocol specification - Type 4 elements**

utarbetad inom International Electrotechnical Commission, IEC.

Denna standard, och de andra delarna i serien SS-EN 61158-4, ersätter SS-EN 61158-4, utgåva 1, 2004.

Tidigare fastställd svensk standard SS-EN 61158-4, utgåva 1, 2004, gäller ej fr o m 2011-02-01.

---

ICS 35.100.20; 25.040.40

## *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

## *SEK är Sveriges röst i standardiseringssarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

## *Stora delar av arbetet sker internationellt*

Utdriften av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringssarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringssverksamhet och medlemsavgift till IEC och CENELEC.

## *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtidens standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

## **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English version

**Industrial communication networks -  
Fieldbus specifications -  
Part 4-4: Data-link layer protocol specification -  
Type 4 elements  
(IEC 61158-4-4:2007)**

Réseaux de communication industriels -  
Spécifications des bus de terrain -  
Partie 4-4: Spécification des protocoles  
des couches de liaison de données -  
Eléments de type 4  
(CEI 61158-4-4:2007)

Industrielle Kommunikationsnetze -  
Feldbusse -  
Teil 4-4: Protokollspezifikation des  
Data Link Layer (Sicherungsschicht) -  
Typ 4-Elemente  
(IEC 61158-4-4:2007)

This European Standard was approved by CENELEC on 2008-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 65C/474/FDIS, future edition 1 of IEC 61158-4-4, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61158-4-4 on 2008-02-01.

This and the other parts of the EN 61158-4 series supersede EN 61158-4:2004.

With respect to EN 61158-4:2004 the following changes were made:

- deletion of Type 6 fieldbus, and the placeholder for a Type 5 fieldbus data-link layer, for lack of market relevance;
- addition of new fieldbus types;
- partition into multiple parts numbered 4-1, 4-2, ..., 4-19.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2008-11-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2011-02-01

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the EN 61784 series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

Annex ZA has been added by CENELEC.

---

## Endorsement notice

The text of the International Standard IEC 61158-4-4:2007 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60870-5-1	NOTE Harmonized as EN 60870-5-1:1993 (not modified).
IEC 61131-2	NOTE Harmonized as EN 61131-2:2007 (not modified).
IEC 61131-3	NOTE Harmonized as EN 61131-3:2003 (not modified).
IEC 61158-5-4	NOTE Harmonized as EN 61158-5-4:2008 (not modified).
IEC 61158-6-4	NOTE Harmonized as EN 61158-6-4:2008 (not modified).
IEC 61784-1	NOTE Harmonized as EN 61784-1:2008 (not modified).
IEC 61784-2	NOTE Harmonized as EN 61784-2:2008 (not modified).
ISO/IEC 9646-1	NOTE Harmonized as EN ISO/IEC 9646-1:1996 (not modified).
ISO/IEC 9646-2	NOTE Harmonized as EN ISO/IEC 9646-2:1996 (not modified).
ISO 9314-2	NOTE Harmonized as EN 29314-2:1993 (not modified).

## Annex ZA

(normative)

### **Normative references to international publications with their corresponding European publications**

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 61158-2	2007	Industrial communication networks - Fieldbus specifications - Part 2: Physical layer specification and service definition	EN 61158-2	2008
IEC 61158-3-4	<sup>-1)</sup>	Industrial communication networks - Fieldbus specifications - Part 3-4: Data-link layer service definition - Type 4 elements	EN 61158-3-4	2008 <sup>2)</sup>
ISO/IEC 7498-1	<sup>-1)</sup>	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	EN ISO/IEC 7498-1	1995 <sup>2)</sup>
ISO/IEC 7498-3	<sup>-1)</sup>	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 10731	<sup>-1)</sup>	Information technology - Open Systems Interconnection - Basic reference model - Conventions for the definition of OSI services	-	-

<sup>1)</sup> Undated reference.

<sup>2)</sup> Valid edition at date of issue.



## CONTENTS

INTRODUCTION.....	6
1 Scope.....	7
1.1 General .....	7
1.2 Specifications .....	7
1.3 Procedures.....	7
1.4 Applicability.....	7
1.5 Conformance.....	7
2 Normative references .....	8
3 Terms, definitions, symbols and abbreviations.....	8
3.1 Reference model terms and definitions.....	8
3.2 Service convention terms and definitions.....	10
3.3 Terms and definitions .....	11
3.4 Symbols and abbreviations.....	14
4 Data Link Protocol Definition .....	14
4.1 Overview of the DL-protocol .....	14
4.2 General structure and encoding of PhIDUs and DLPDUs, and related elements of procedure.....	26
4.3 DLPDU-specific structure, encoding and elements of procedure.....	33
4.4 DL-service elements of procedure .....	37
4.5 Route mechanism.....	40
4.6 Link-access system .....	43
4.7 Local variables, counters and queues.....	44
Bibliography.....	46
Figure 1 – Relationship of PhE, DLE and DLS-user .....	15
Figure 2 – DLE state diagram for confirmed and unconfirmed, unacknowledged DLPDUs .....	17
Figure 3 – DLE state diagram for confirmed acknowledged DLPDUs.....	18
Figure 4 – DLE state diagram for unconfirmed acknowledged DLPDUs.....	19
Figure 5 – Full duplex DLE receive state diagram .....	20
Figure 6 – Full duplex DLE transmit state diagram .....	20
Figure 7 – Link access example .....	23
Figure 8 – Simple Type 4-route format .....	29
Figure 9 – Extended Type 4-route format .....	29
Figure 10 – Complex Type 4-route format .....	30
Figure 11 – Immediate Type 4-route format .....	30
Figure 12 – IP Type 4-route format .....	31
Figure 13 – Control-status format.....	32
Figure 14 – Data-field-format .....	32
Figure 15 – Source / destination designator .....	41
Figure 16 – Simple Type 4-route generation .....	41
Figure 17 – Extended Type 4-route generation .....	42
Figure 18 – Complex and IP Type 4-route generation .....	42

Figure 19 – Simple DL-route generation.....	43
Figure 20 – Extended DL-route generation.....	43
Figure 21 – Complex and IP DL-route generation.....	43
Table 1 – Summary structure of DLPDUs .....	33
Table 2 – Structure of Confirmed DLPDUs .....	34
Table 3 – Structure of Unconfirmed DLPDUs .....	35
Table 4 – Structure of Acknowledge DLPDU .....	36
Table 5 – Structure of Immediate-reply DLPDU .....	36

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The data-link protocol provides the data-link service by making use of the services available from the physical layer. The primary aim of this standard is to provide a set of rules for communication expressed in terms of the procedures to be carried out by peer data-link entities (DLEs) at the time of communication. These rules for communication are intended to provide a sound basis for development in order to serve a variety of purposes:

- a) as a guide for implementors and designers;
- b) for use in the testing and procurement of equipment;
- c) as part of an agreement for the admittance of systems into the open systems environment;
- d) as a refinement to the understanding of time-critical communications within OSI.

This standard is concerned, in particular, with the communication and interworking of sensors, effectors and other automation devices. By using this standard together with other standards positioned within the OSI or fieldbus reference models, otherwise incompatible systems may work together in any combination.

## INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

### Part 4-4: Data-link layer protocol specification – Type 4 elements

## 1 Scope

### 1.1 General

The data-link layer provides basic time-critical messaging communications between devices in an automation environment.

This protocol provides a means of connecting devices through a partial mesh network, such that most failures of an interconnection between two devices can be circumvented. In common practice the devices are interconnected in a non-redundant hierarchical manner reflecting application needs

### 1.2 Specifications

This standard specifies

- a) procedures for the timely transfer of data and control information from one data-link user entity to a peer user entity, and among the data-link entities forming the distributed data-link service provider;
- b) the structure of the fieldbus DLPDUs used for the transfer of data and control information by the protocol of this standard, and their representation as physical interface data units.

### 1.3 Procedures

The procedures are defined in terms of

- a) the interactions between peer DL-entities (DLEs) through the exchange of fieldbus DLPDUs;
- b) the interactions between a DL-service (DLS) provider and a DLS-user in the same system through the exchange of DLS primitives;
- c) the interactions between a DLS-provider and a Ph-service provider in the same system through the exchange of Ph-service primitives.

### 1.4 Applicability

These procedures are applicable to instances of communication between systems which support time-critical communications services within the data-link layer of the OSI or fieldbus reference models, and which require the ability to interconnect in an open systems interconnection environment.

Profiles provide a simple multi-attribute means of summarizing an implementation's capabilities, and thus its applicability to various time-critical communications needs.

### 1.5 Conformance

This standard also specifies conformance requirements for systems implementing these procedures. This standard does not contain tests to demonstrate compliance with such requirements.