

© Copyright SEK. Reproduction in any form without permission is prohibited.

## Industriell processstyrning – Fältbuss – Del 5-2: Definition av tjänster i applikationsskiktet – Delar i fältbuss, Typ 2

*Industrial communication networks –  
Fieldbus specifications –  
Part 5-2: Application layer service definition –  
Type 2 elements*

Som svensk standard gäller europastandarden EN 61158-5-2:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61158-5-2:2008.

### Nationellt förord

Europastandarden EN 61158-5-2:2008

består av:

- europastandardens ikraftsättningsdokument, utarbetat inom CENELEC
- IEC 61158-5-2, First edition, 2007 - Industrial communication networks - Fieldbus specifications - Part 5-2: Application layer service definition - Type 2 elements

utarbetad inom International Electrotechnical Commission, IEC.

Denna standard, och de andra delarna i serien SS-EN 61158-5, ersätter SS-EN 61158-5, utgåva 1, 2004.

Tidigare fastställd svensk standard SS-EN 61158-5, utgåva 1, 2004, gäller ej fr o m 2011-02-01.

---

ICS 35.100.70; 25.040.40

## *Standarder underlättar utvecklingen och höjer elsäkerheten*

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

## *SEK är Sveriges röst i standardiseringssarbetet inom elområdet*

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

## *Stora delar av arbetet sker internationellt*

Utdriften av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringssarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringssverksamhet och medlemsavgift till IEC och CENELEC.

## *Var med och påverka!*

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

## **SEK Svensk Elstandard**

Box 1284  
164 29 Kista  
Tel 08-444 14 00  
[www.elstandard.se](http://www.elstandard.se)

English version

**Industrial communication networks -  
Fieldbus specifications -  
Part 5-2: Application layer service definition -  
Type 2 elements  
(IEC 61158-5-2:2007)**

Réseaux de communication industriels -  
Spécifications des bus de terrain -  
Partie 5-2: Définition des services  
des couches d'application -  
Eléments de type 2  
(CEI 61158-5-2:2007)

Industrielle Kommunikationsnetze -  
Feldbusse -  
Teil 5-2: Dienstfestlegungen  
des Application Layer  
(Anwendungsschicht) -  
Typ 2-Elemente  
(IEC 61158-5-2:2007)

This European Standard was approved by CENELEC on 2008-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

**CENELEC**

European Committee for Electrotechnical Standardization  
Comité Européen de Normalisation Electrotechnique  
Europäisches Komitee für Elektrotechnische Normung

**Central Secretariat: rue de Stassart 35, B - 1050 Brussels**

## Foreword

The text of document 65C/475/FDIS, future edition 1 of IEC 61158-5-2, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61158-5-2 on 2008-02-01.

This and the other parts of the EN 61158-5 series supersede EN 61158-5:2004.

With respect to EN 61158-5:2004 the following changes were made:

- deletion of Type 6 fieldbus for lack of market relevance;
- addition of new fieldbus types;
- partition into multiple parts numbered 5-2, 5-3, ..., 5-20.

The following dates were fixed:

- latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2008-11-01
- latest date by which the national standards conflicting with the EN have to be withdrawn (dow) 2011-02-01

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the EN 61784 series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

Annex ZA has been added by CENELEC.

---

## Endorsement notice

The text of the International Standard IEC 61158-5-2:2007 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61131-1	NOTE Harmonized as EN 61131-1:2003 (not modified).
IEC 61158-2	NOTE Harmonized as EN 61158-2:2008 (not modified).
IEC 61158-3-2	NOTE Harmonized as EN 61158-3-2:2008 (not modified).
IEC 61784-1	NOTE Harmonized as EN 61784-1:2008 (not modified).
IEC 61784-2	NOTE Harmonized as EN 61784-2:2008 (not modified).

---

## Annex ZA

(normative)

### Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60559	- <sup>1)</sup>	Binary floating-point arithmetic for microprocessor systems	HD 592 S1	1991 <sup>2)</sup>
IEC 61131-3	2003	Programmable controllers - Part 3: Programming languages	EN 61131-3	2003
IEC 61158-4-2	- <sup>1)</sup>	Industrial communication networks - Fieldbus specifications - Part 4-2: Data-link layer protocol specification - Type 2 elements	EN 61158-4-2	2008 <sup>2)</sup>
IEC 61158-6-2	- <sup>1)</sup>	Industrial communication networks - Fieldbus specifications - Part 6-2: Application layer protocol specification - Type 2 elements	EN 61158-6-2	2008 <sup>2)</sup>
IEC 61588	2004	Precision clock synchronization protocol for networked measurement and control systems	-	-
IEC 61784-3-2	- <sup>1)</sup>	Industrial communication networks - Profiles - - Part 3-2: Functional safety fieldbuses - Additional specifications for CPF 2	-	-
ISO/IEC 646	- <sup>1)</sup>	Information technology - ISO 7-bit coded character set for information interchange	-	-
ISO/IEC 7498-1	- <sup>1)</sup>	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	EN ISO/IEC 7498-1	1995 <sup>2)</sup>
ISO/IEC 7498-3	- <sup>1)</sup>	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 8822	- <sup>1)</sup>	Information technology - Open Systems Interconnection - Presentation service definition	-	-
ISO/IEC 8824	- <sup>1)</sup>	Information technology - Open Systems Interconnection - Specification of Abstract Syntax Notation One (ASN.1)	-	-

<sup>1)</sup> Undated reference.

<sup>2)</sup> Valid edition at date of issue.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 8859-1	- <sup>1)</sup>	Information technology - 8-bit single-byte coded graphic character sets - Part 1: Latin alphabet No.1	-	-
ISO/IEC 9545	- <sup>1)</sup>	Information technology - Open Systems Interconnection - Application Layer structure	-	-
ISO/IEC 10646-1	- <sup>1)</sup>	Information technology - Universal Multiple-Octet Coded Character Set (UCS) - Part 1: Architecture and Basic Multilingual Plane	-	-
ISO/IEC 10731	- <sup>1)</sup>	Information technology - Open Systems Interconnection - Basic reference model - Conventions for the definition of OSI services	-	-
ISO 11898	1993	Road vehicles - Interchange of digital information - Controller area network (CAN) for high-speed communication	-	-

## CONTENTS

INTRODUCTION.....	7
1 Scope.....	8
1.1 Overview .....	8
1.2 Specifications .....	9
1.3 Conformance.....	9
2 Normative references .....	9
3 Terms, definitions, symbols, abbreviations and conventions .....	10
3.1 ISO/IEC 7498-1 terms .....	10
3.2 ISO/IEC 8822 terms .....	10
3.3 ISO/IEC 9545 terms .....	11
3.4 ISO/IEC 8824 terms .....	11
3.5 Type 2 fieldbus data-link layer terms .....	11
3.6 Type 2 fieldbus application-layer specific definitions.....	11
3.7 Type 2 abbreviations and symbols.....	19
3.8 Conventions .....	20
4 Common concepts.....	22
5 Data type ASE.....	23
5.1 General .....	23
5.2 Formal definition of data type objects .....	23
5.3 FAL defined data types.....	23
5.4 Data type ASE service specification .....	33
6 Communication model specification.....	34
6.1 Concepts.....	34
6.2 ASEs.....	42
6.3 ARs .....	148
6.4 Summary of FAL classes .....	185
6.5 Permitted FAL services by AR type .....	186
Bibliography.....	188
 Figure 1 – Overview of ASEs and object classes .....	36
Figure 2 – Addressing format using MAC, class, instance and attribute IDs .....	36
Figure 3 – Identity object state transition diagram .....	54
Figure 4 – Static Assembly state transition diagram .....	59
Figure 5 – Dynamic Assembly state transition diagram .....	60
Figure 6 – Typical timing relationships for acknowledged data production.....	69
Figure 7 – Example of a COS system with two acking devices .....	69
Figure 8 – Message flow in COS connection – one Connection object, one consumer.....	69
Figure 9 – Message flow in COS connection – multiple consumers .....	70
Figure 10 – CPF2 time synchronization offset clock model.....	77
Figure 11 – CPF2 time synchronization system with offset clock model .....	78
Figure 12 – CPF2 time synchronization group startup sequence .....	81
Figure 13 – Example of Find_Next_Object_Instance service .....	106

Figure 14 – Transmission trigger timer .....	142
Figure 15 – Inactivity watchdog timer .....	143
Figure 16 – Using tools for configuration .....	144
Figure 17 – Production inhibit timer .....	145
Figure 18 – Context of transport services within the connection model.....	151
Figure 19 – Application-to-application view of data transfer .....	151
Figure 20 – Data flow diagram for a link producer .....	152
Figure 21 – Data flow diagram for a link consumer.....	153
Figure 22 – Triggers .....	154
Figure 23 – Binding transport instances to the producer and consumer of a transport connection that does not have a reverse data path .....	155
Figure 24 – Binding transport instances to the producers and consumers of a transport connection that does have a reverse data path .....	155
Figure 25 – Binding transport instances to the producer and consumers of a multipoint connection when the transport connection does not have a reverse data path .....	156
Figure 26 – Binding transport instances to the producers and consumers of a multipoint connection when the transport connection does have reverse data paths .....	156
 Table 1 – Valid IANA MIB printer codes for character set selection .....	32
Table 2 – Common elements .....	39
Table 3 – ST language elements.....	40
Table 4 – Type conversion operations.....	40
Table 5 – Values of implementation-dependent parameters .....	41
Table 6 – Extensions to IEC 61131-3 .....	42
Table 7 – Identity object state event matrix .....	55
Table 8 – Static Assembly state event matrix .....	59
Table 9 – Dynamic Assembly state event matrix .....	60
Table 10 – Message Router object Forward_Open parameters .....	63
Table 11 – Acknowledge Handler object state event matrix.....	66
Table 12 – Producing I/O application object state event matrix .....	67
Table 13 – Qos values .....	81
Table 14 – Status codes .....	84
Table 15 – Get_Attribute_All service parameters .....	86
Table 16 – Set_Attribute_All service parameters.....	87
Table 17 – Get_Attribute_List service parameters.....	89
Table 18 – Set_Attribute_List service parameters .....	91
Table 19 – Reset service parameters .....	93
Table 20 – Start service parameters .....	95
Table 21 – Stop service parameters.....	97
Table 22 – Create service parameters .....	98
Table 23 – Delete service parameters.....	100
Table 24 – Get_Attribute_Single service parameters.....	101
Table 25 – Set_Attribute_Single service parameters .....	103
Table 26 – Find_Next_Object_Instance service parameters .....	104

Table 27 – NOP service parameters .....	107
Table 28 – Apply_Attributes service parameters .....	108
Table 29 – Save service parameters .....	110
Table 30 – Restore service parameters.....	111
Table 31 – Group_Sync service parameters.....	113
Table 32 – Add_AckData_Path service parameters.....	115
Table 33 – Remove_AckData_Path service parameters .....	116
Table 34 – Initialize service parameters .....	117
Table 35 – Management_Message service parameters .....	119
Table 36 – CM_Open service parameters .....	127
Table 37 – CM_Close service parameters .....	129
Table 38 – CM_Unconnected_Send service parameters .....	130
Table 39 – CM_Get_Connection_Data service parameters .....	132
Table 40 – CM_Search_Connection_Data service parameters .....	133
Table 41 – CM_Get_Connection_Data service parameters .....	134
Table 42 – I/O Connection object attribute access .....	139
Table 43 – Bridged Connection object attribute access .....	140
Table 44 – Explicit messaging object attribute access.....	141
Table 45 – Connection_Bind service parameters .....	146
Table 46 – Service_Name service parameters .....	147
Table 47 – How production trigger, transport class, and CM_RPI determine when data is produced.....	150
Table 48 – Transport classes .....	161
Table 49 – UCMM_Create service parameters .....	178
Table 50 – UCMM_Delete service parameters .....	179
Table 51 – UCMM_Write service parameters .....	180
Table 52 – UCMM_Abort service parameters .....	181
Table 53 – TR_Write service parameters .....	182
Table 54 – TR_Trigger service parameters .....	183
Table 55 – TR_Packet_arrived service parameters .....	183
Table 56 – TR_Ack_received service parameters.....	184
Table 57 – TR_Verify service parameters .....	184
Table 58 – TR_Status_updated service parameters .....	185
Table 59 – FAL class summary .....	186
Table 60 – FAL services by AR type .....	187

## INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

The application service is provided by the application protocol making use of the services available from the data-link or other immediately lower layer. This standard defines the application service characteristics that fieldbus applications and/or system management may exploit.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the application layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

## INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

### Part 5-2: Application layer service definition – Type 2 elements

## 1 Scope

### 1.1 Overview

The fieldbus application layer (FAL) provides user programs with a means to access the fieldbus communication environment. In this respect, the FAL can be viewed as a “window between corresponding application programs.”

This standard provides common elements for basic time-critical and non-time-critical messaging communications between application programs in an automation environment and material specific to Type 2 fieldbus. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 2 fieldbus application layer in terms of

- a) an abstract model for defining application resources (objects) capable of being manipulated by users via the use of the FAL service;
- b) the primitive actions and events of the service;
- c) the parameters associated with each primitive action and event, and the form which they take; and
- d) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- 1) the FAL user at the boundary between the user and the application layer of the fieldbus reference model, and
- 2) Systems Management at the boundary between the application layer and Systems Management of the fieldbus reference model.

This standard specifies the structure and services of the Type 2 fieldbus application layer, in conformance with the OSI Basic Reference Model (ISO/IEC 7498) and the OSI application layer structure (ISO/IEC 9545).

FAL services and protocols are provided by FAL application-entities (AE) contained within the application processes. The FAL AE is composed of a set of object-oriented application service elements (ASEs) and a layer management entity (LME) that manages the AE. The ASEs provide communication services that operate on a set of related application process object (APO) classes. One of the FAL ASEs is a management ASE that provides a common set of services for the management of the instances of FAL classes.

Although these services specify, from the perspective of applications, how request and responses are issued and delivered, they do not include a specification of what the requesting and responding applications are to do with them. That is, the behavioral aspects of the applications are not specified; only a definition of what requests and responses they can send/receive is specified. This permits greater flexibility to the FAL users in standardizing

such object behavior. In addition to these services, some supporting services are also defined in this standard to provide access to the FAL to control certain aspects of its operation.

## 1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual application layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of application layer protocols for time-critical communications.

A secondary objective is to provide migration paths from previously-existing industrial communications protocols. It is this latter objective which gives rise to the diversity of services standardized as the various Types of IEC 61158, and the corresponding protocols standardized in subparts of IEC 61158-6.

This specification may be used as the basis for formal application programming interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

## 1.3 Conformance

This standard does not specify individual implementations or products, nor does it constrain the implementations of application layer entities within industrial automation systems.

There is no conformance of equipment to this application layer service definition standard. Instead, conformance is achieved through implementation of conforming application layer protocols that fulfill the Type 2 application layer services as defined in this standard.

## 2 Normative references

The following referenced standards are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced standard (including any amendments) applies.

IEC 60559, *Binary floating-point arithmetic for microprocessor systems*

IEC 61131-3:2003, *Programmable controllers – Part 3: Programming languages*

IEC 61158-4-2, *Industrial communication networks – Fieldbus specifications – Part 4-2: Data-link layer protocol specification – Type 2 elements*

IEC 61158-6-2, *Industrial communication networks – Fieldbus specifications – Part 6-2: Application layer protocol specification – Type 2 elements*

IEC 61588:20041, *Precision clock synchronization protocol for networked measurement and control systems*

IEC 61784-3-2, *Industrial communications networks – Profiles – Part 3-2: Functional safety fieldbuses – Additional specifications for CPF 2*

---

<sup>1</sup> Compliance with future editions of this standard will need checking.