

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Fältbuss – Del 3-3: Definition av tjänster i datalänkskiktet – Delar i fältbuss, Typ 3

*Industrial communication networks –
Fieldbus specifications –
Part 3-3: Data-link layer service definition –
Type 3 elements*

Som svensk standard gäller europastandarden EN 61158-3-3:2008. Den svenska standarden innehåller den officiella engelska språkversionen av EN 61158-3-3:2008.

Nationellt förord

Europastandarden EN 61158-3-3:2008

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 61158-3-3, First edition, 2007 - Industrial communication networks - Fieldbus specifications - Part 3-3: Data-link layer service definition - Type 3 elements**

utarbetad inom International Electrotechnical Commission, IEC.

Denna standard, och de andra delarna i serien SS-EN 61158-3, ersätter SS-EN 61158-3, utgåva 1, 2004.

Tidigare fastställd svensk standard SS-EN 61158-3, utgåva 1, 2004, gäller ej fr o m 2011-02-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Industrial communication networks -
Fieldbus specifications -
Part 3-3: Data-link layer service definition -
Type 3 elements
(IEC 61158-3-3:2007)**

Réseaux de communication industriels -
Spécifications des bus de terrain -
Partie 3-3: Définition des services
des couches de liaison de données -
Éléments de type 3
(CEI 61158-3-3:2007)

Industrielle Kommunikationsnetze -
Feldbusse -
Teil 3-3: Dienstfestlegungen
des Data Link Layer (Sicherheitsschicht) -
Typ 3-Elemente
(IEC 61158-3-3:2007)

This European Standard was approved by CENELEC on 2008-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

The text of document 65C/473/FDIS, future edition 1 of IEC 61158-3-3, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 61158-3-3 on 2008-02-01.

This and the other parts of the EN 61158-3 series supersede EN 61158-3:2004.

With respect to EN 61158-3:2004 the following changes were made:

- deletion of Type 6 fieldbus, and the placeholder for a Type 5 fieldbus data-link layer, for lack of market relevance;
- addition of new fieldbus types;
- partition into multiple parts numbered 3-1, 3-2, ..., 3-19.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2008-11-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2011-02-01

NOTE Use of some of the associated protocol types is restricted by their intellectual-property-right holders. In all cases, the commitment to limited release of intellectual-property-rights made by the holders of those rights permits a particular data-link layer protocol type to be used with physical layer and application layer protocols in type combinations as specified explicitly in the EN 61784 series. Use of the various protocol types in other combinations may require permission from their respective intellectual-property-right holders.

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 61158-3-3:2007 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 61158-2	NOTE Harmonized as EN 61158-2:2008 (not modified).
IEC 61158-4-3	NOTE Harmonized as EN 61158-4-3:2008 (not modified).
IEC 61158-5-3	NOTE Harmonized as EN 61158-5-3:2008 (not modified).
IEC 61158-6-3	NOTE Harmonized as EN 61158-6-3:2008 (not modified).
IEC 61784-1	NOTE Harmonized as EN 61784-1:2008 (not modified).
IEC 61784-2	NOTE Harmonized as EN 61784-2:2008 (not modified).

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
ISO/IEC 7498-1	- ¹⁾	Information technology - Open Systems Interconnection - Basic Reference Model: The Basic Model	EN ISO/IEC 7498-1	1995 ²⁾
ISO/IEC 7498-3	- ¹⁾	Information technology - Open Systems Interconnection - Basic Reference Model: Naming and addressing	-	-
ISO/IEC 10731	- ¹⁾	Information technology - Open Systems Interconnection - Basic Reference Model - Conventions for the definition of OSI services	-	-

¹⁾ Undated reference.

²⁾ Valid edition at date of issue.

CONTENTS

INTRODUCTION.....	7
1 Scope.....	8
1.1 Overview.....	8
1.2 Specifications.....	8
1.3 Conformance.....	8
2 Normative references.....	9
3 Terms, definitions, symbols, abbreviations and conventions.....	9
3.1 Reference model terms and definitions.....	9
3.2 Service convention terms and definitions.....	10
3.3 Common data-link service terms and definitions.....	11
3.4 Additional Type 3 data-link specific definitions.....	13
3.5 Common symbols and abbreviations.....	15
3.6 Additional Type 3 symbols and abbreviations.....	16
3.7 Common conventions.....	18
3.8 Additional Type 3 conventions.....	19
4 Connectionless-mode data-link service.....	19
4.1 General.....	19
4.2 Model of the connectionless-mode data-link service.....	20
4.3 Sequence of primitives.....	21
4.4 Detailed description of DL services.....	25
5 DL-management Service.....	44
5.1 General.....	44
5.2 Facilities of the DLMS.....	44
5.3 Services of the DL-management.....	44
5.4 Overview of interactions.....	46
5.5 Detailed specification of services and interactions.....	47
Bibliography.....	68
Figure 1 – Relationships of DLSAPs, DLSAP-addresses and group DL-addresses.....	12
Figure 2 – SDA service.....	22
Figure 3 – SDN service.....	23
Figure 4 – SRD service.....	23
Figure 5 – MSRD service.....	24
Figure 6 – CS service.....	24
Figure 7 – Reset, Set value, Get value, Ident (local), DLSAP status, DLSAP activate, DLSAP activate responder, DLSAP activate subscriber and DLSAP deactivate services.....	47
Figure 8 – Event service.....	47
Figure 9 – Ident (remote) service.....	47
Table 1 – Summary of DL services and primitives.....	22
Table 2 – SDA data ack primitives and parameters.....	26
Table 3 – Values of DL_status for the SDA data ack service.....	28
Table 4 – SDN data primitives and parameters.....	29

Table 5 – Values of DL_status for the SDN data service	30
Table 6 – SRD data reply primitives and parameters.....	32
Table 7 – Values of Update_status for the SRD data reply service	33
Table 8 – Additional values of DL_status for the SRD data reply service	34
Table 9 – SRD reply-update primitives and parameters.....	34
Table 10 – Values of DL_status for the SRD reply-update service	35
Table 11 – MSRD MCT data reply primitives and parameters.....	37
Table 12 – MSRD DXM data reply primitive and parameters	39
Table 13 – CS time event primitives and parameters	40
Table 14 – Values of DL_status for the CS time event service	42
Table 15 – CS clock value primitives and parameters	42
Table 16 – Values of CS_status for the CS clock value service	43
Table 17 – Values of DL_status for the CS clock value service	44
Table 18 – Summary of DL-management services and primitives	46
Table 19 – Reset primitives and parameters	47
Table 20 – Values of DLM_status for the reset service.....	48
Table 21 – Set value primitives and parameters.....	48
Table 22 – Mandatory DLE-variables	49
Table 23 – Optional DLE-variables	49
Table 24 – Permissible values of mandatory DLE-variables	50
Table 25 – Permissible values of optional DLE-variables	50
Table 26 – Meaning of the values for the parameter isochronous_mode.....	51
Table 27 – Default reaction times and operating parameters for a master station for asynchronous transmission.....	51
Table 28 – Default reaction times and operating parameters for a slave station with asynchronous transmission.....	51
Table 29 – Default reaction times and operating parameters for master stations for coupling of synchronous and asynchronous transmission segments	52
Table 30 – Default reaction times and operating parameter for slave stations for coupling of synchronous and asynchronous transmission segments	52
Table 31 – Values of DLM_status for the set value service	52
Table 32 – Get value primitives and parameters	53
Table 33 – Additional mandatory DLE-variables in master stations.....	53
Table 34 – Permissible values of the additional DLE-variables in master stations.....	54
Table 35 – Values of DLM_status for the get value service	54
Table 36 – Event primitive and parameters.....	55
Table 37 – Mandatory DLL events and fault types	55
Table 38 – Permissible values of T _{SH}	55
Table 39 – Ident primitives and parameters	56
Table 40 – Ident_list for the ident service	57
Table 41 – Values of DLM_status for the ident service (local)	57
Table 42 – Values of DLM_status for the ident service (remote).....	57
Table 43 – DLSAP status primitives and parameters.....	58
Table 44 – Values of DLM_status for the DLSAP status service	59

Table 45 – DLSAP activate primitives and parameters	59
Table 46 – DLSAP activate service_list.....	60
Table 47 – DLSAP activate DLSDU_length_list (SDA, SDN, SRD, MSRD and CS)	61
Table 48 – DLSDU lengths of SDA and SDN as used in the DLSAP activate service	61
Table 49 – DLSDU lengths of SRD and MSRD as used in the (master station) DLSAP activate service	61
Table 50 – DLSDU lengths of CS as used in the DLSAP activate service	62
Table 51 – Values of DLM_status for the DLSAP activate service	62
Table 52 – DLSAP activate responder primitives and parameters.....	62
Table 53 – DLSDU_length_list for the DLSAP activate responder service.....	63
Table 54 – DLSDU length of SRD and MSRD as used in the DLSAP activate responder service	63
Table 55 – Values of DLM_status for the DLSAP activate responder service	64
Table 56 – DLSAP activate subscriber primitives and parameters	65
Table 57 – DLSDU_length_list for the DLSAP activate subscriber service	65
Table 58 – DLSDU lengths of MSRD as used in the DLSAP activate subscriber service (master and slave stations).....	65
Table 59 – Values of DLM_status for the DLSAP activate subscriber service	66
Table 60 – DLSAP deactivate primitives and parameters	66
Table 61 – Values of DLM_status for the DLSAP deactivate service.....	67

INTRODUCTION

This part of IEC 61158 is one of a series produced to facilitate the interconnection of automation system components. It is related to other standards in the set as defined by the “three-layer” fieldbus reference model described in IEC/TR 61158-1.

Throughout the set of fieldbus standards, the term “service” refers to the abstract capability provided by one layer of the OSI Basic Reference Model to the layer immediately above. Thus, the data-link layer service defined in this standard is a conceptual architectural service, independent of administrative and implementation divisions.

INDUSTRIAL COMMUNICATION NETWORKS – FIELDBUS SPECIFICATIONS –

Part 3-3: Data-link layer service definition – Type 3 elements

1 Scope

1.1 Overview

This part of IEC 61158 provides common elements for basic time-critical messaging communications between devices in an automation environment. The term “time-critical” is used to represent the presence of a time-window, within which one or more specified actions are required to be completed with some defined level of certainty. Failure to complete specified actions within the time window risks failure of the applications requesting the actions, with attendant risk to equipment, plant and possibly human life.

This standard defines in an abstract way the externally visible service provided by the Type 3 fieldbus data-link layer in terms of

- a) the primitive actions and events of the service;
- b) the parameters associated with each primitive action and event, and the form which they take; and
- c) the interrelationship between these actions and events, and their valid sequences.

The purpose of this standard is to define the services provided to

- the Type 3 fieldbus application layer at the boundary between the application and data-link layers of the fieldbus reference model, and
- systems management at the boundary between the data-link layer and systems management of the fieldbus reference model.

1.2 Specifications

The principal objective of this standard is to specify the characteristics of conceptual data-link layer services suitable for time-critical communications, and thus supplement the OSI Basic Reference Model in guiding the development of data-link protocols for time-critical communications. A secondary objective is to provide migration paths from previously existing industrial communications protocols.

This specification may be used as the basis for formal DL-Programming-Interfaces. Nevertheless, it is not a formal programming interface, and any such interface will need to address implementation issues not covered by this specification, including

- a) the sizes and octet ordering of various multi-octet service parameters, and
- b) the correlation of paired request and confirm, or indication and response, primitives.

1.3 Conformance

This standard does not specify individual implementations or products, nor do they constrain the implementations of data-link entities within industrial automation systems.

There is no conformance of equipment to this data-link layer service definition standard. Instead, conformance is achieved through implementation of the corresponding data-link protocol that fulfills the Type 1 data-link layer services defined in this standard.