

© Copyright SEK. Reproduction in any form without permission is prohibited.

Kopplingsapparater för högst 1000 V – Part 7-1: Övrigt hithörande materiel – Kopplingsplintar för kopparledare

*Low-voltage switchgear and controlgear –
Part 7-1: Ancillary equipment –
Terminal blocks for copper conductors*

Som svensk standard gäller europastandarden EN 60947-7-1:2009. Den svenska standarden innehåller den officiella engelska språkversionen av EN 60947-7-1:2009.

Nationellt förord

Europastandarden EN 60947-7-1:2009

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60947-7-1, Third edition, 2009 - Low-voltage switchgear and controlgear - Part 7-1: Ancillary equipment - Terminal blocks for copper conductors**

utarbetad inom International Electrotechnical Commission, IEC.

Standarden ska användas tillsammans med SS-EN 60947-1.

Tidigare fastställd svensk standard SS-EN 60947-7-1, utgåva 2, 2003, gäller ej fr o m 2012-06-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Low-voltage switchgear and controlgear -
Part 7-1: Ancillary equipment -
Terminal blocks for copper conductors
(IEC 60947-7-1:2009)**

Appareillage à basse tension -
Partie 7-1: Matériels accessoires -
Blocs de jonction
pour conducteurs en cuivre
(CEI 60947-7-1:2009)

Niederspannungsschaltgeräte -
Teil 7-1: Hilfseinrichtungen -
Reihenklempen für Kupferleiter
(IEC 60947-7-1:2009)

This European Standard was approved by CENELEC on 2009-06-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 17B/1654/FDIS, future edition 3 of IEC 60947-7-1, prepared by SC 17B, Low-voltage switchgear and controlgear, of IEC TC 17, Switchgear and controlgear, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60947-7-1 on 2009-06-01.

This European Standard supersedes EN 60947-7-1:2002.

The main technical modifications of EN 60947-7-1:2009 since EN 60947-7-1:2002 are listed below:

- added in the scope that EN 60947-7-1:2009 may be used as a guide for special types of terminal blocks, for example with diodes or varistors or similar component holders;
- the conventional free air thermal current added in 5.2 in the list of information to be stated by the manufacturer;
- update of 7.1.4 that the colour combination green-yellow is not allowed for terminal blocks;
- the consequences in case of failed single tests and failed tests within test sequences specified in 8.2;
- requirements regarding clearances and creepage distances replaced by reference to Annex H of EN 60947-1, Annex A deleted;
- requirements for tightening torques for the tests improved and referenced to Table 4 of EN 60947-1, Annex C deleted;
- in 8.3.3.3 changed reference for pull-out force to EN 60947-1;
- the wording of the test of the voltage drop improved in 8.4.4;
- the wording of the short-time withstand current test improved in 8.4.6;
- Annex D with additional requirements for test disconnect terminal blocks added. The scope has been modified accordingly.

This standard shall be read in conjunction with EN 60947-1. The provisions of the general rules dealt with in EN 60947-1 are applicable to this standard, where specifically called for. Clauses and subclauses, tables, figures and annexes thus applicable are identified by reference to EN 60947-1, e.g. 1.2 of EN 60947-1, Table 4 of EN 60947-1 or Annex A of EN 60947-1.

The following dates were fixed:

- latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement (dop) 2010-03-01
- latest date by which the national standards conflicting
with the EN have to be withdrawn (dow) 2012-06-01

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60947-7-1:2009 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 60228	NOTE Harmonized as EN 60228:2005 (not modified).
IEC 60715	NOTE Harmonized as EN 60715:2001 (not modified).

Annex ZA

(normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60695-11-5	2004	Fire hazard testing - Part 11-5: Test flames - Needle-flame test method - Apparatus, confirmatory test arrangement and guidance	EN 60695-11-5	2005
IEC 60947-1	2007	Low-voltage switchgear and controlgear - Part 1: General rules	EN 60947-1	2007
ISO 4046-4	2002	Paper, board, pulps and related terms - Vocabulary - Part 4: Paper and board grades and converted products	-	-

CONTENTS

1	General	6
1.1	Scope.....	6
1.2	Normative references	6
2	Definitions	7
3	Classification.....	7
4	Characteristics	7
4.1	Summary of characteristics	7
4.2	Type of terminal block	7
4.3	Rated and limiting values	8
4.3.1	Rated voltages	8
4.3.2	Short-time withstand current.....	8
4.3.3	Standard cross-sections	8
4.3.4	Rated cross-section.....	8
4.3.5	Rated connecting capacity.....	9
5	Product information	9
5.1	Marking.....	9
5.2	Additional information.....	9
6	Normal service, mounting and transport conditions.....	10
7	Constructional and performance requirements.....	10
7.1	Constructional requirements	10
7.1.1	Clamping units.....	10
7.1.2	Mounting	10
7.1.3	Clearances and creepage distances	10
7.1.4	Terminal identification and marking	10
7.1.5	Resistance to abnormal heat and fire.....	11
7.1.6	Rated cross-section and rated connecting capacity	11
7.2	Performance requirements	11
7.2.1	Temperature-rise	11
7.2.2	Dielectric properties.....	11
7.2.3	Short-time withstand current.....	11
7.2.4	Voltage drop.....	12
7.2.5	Electrical performance after ageing (for screwless-type terminal blocks only)	12
7.3	Electromagnetic compatibility (EMC)	12
8	Tests	12
8.1	Kinds of test	12
8.2	General.....	12
8.3	Verification of mechanical characteristics	13
8.3.1	General	13
8.3.2	Attachment of the terminal block on its support.....	13
8.3.3	Mechanical properties of clamping units	14
8.4	Verification of electrical characteristics.....	15
8.4.1	General	15
8.4.2	Verification of clearances and creepage distances	16
8.4.3	Dielectric tests.....	16

8.4.4	Verification of the voltage drop	16
8.4.5	Temperature-rise test	18
8.4.6	Short-time withstand current test	19
8.4.7	Ageing test (for screwless-type terminal blocks only).....	19
8.5	Verification of thermal characteristics	20
8.6	Verification of EMC characteristics	22
8.6.1	Immunity	22
8.6.2	Emission	22
Annex A	vacant.....	23
Annex B (informative)	Items subject to agreement between manufacturer and user	24
Annex C	vacant	25
Annex D (normative)	Additional requirements for test disconnect terminal blocks.....	26
Bibliography		34
Figure 1	– Arrangement for test according to 8.3.2	13
Figure 2	– Arrangement for tests according to 8.4.5 and 8.4.7, and for the verification of voltage drop.....	18
Figure 3	– Arrangement for test according to 8.5	21
Figure 4	– Point of test flame contact (view from the layer placed below the terminal block)	22
Figure D.1	– Test requirements according to D.8.4.4 for verification of the voltage drop	30
Table 1	– Standard cross-sections of round copper conductors.....	8
Table 2	– Relationship between rated cross-section and rated connecting capacity of terminal blocks	9
Table 3	– Attachment test parameters.....	14
Table 4	– Values of test current for temperature-rise test, ageing test and voltage drop verification for metric wire sizes	17
Table 5	– Values of test current for temperature-rise test, ageing test and voltage drop verification for AWG or kcmil wire sizes	18
Table D.1	– Operating cycles	28
Table D.2	– Values of test current for temperature-rise test, ageing test and voltage drop verification for metric wire sizes	30
Table D.3	– Values of test current for temperature-rise test, ageing test and voltage drop verification for AWG or kcmil wire sizes	30
Table D.4	– Short-time withstand current and corresponding wire sizes in mm ²	31
Table D.5	– Short-time withstand current and corresponding wire sizes in AWG	32

LOW-VOLTAGE SWITCHGEAR AND CONTROLGEAR –

Part 7-1: Ancillary equipment – Terminal blocks for copper conductors

1 General

1.1 Scope

This part of IEC 60947 specifies requirements for terminal blocks with screw-type or screw-less-type clamping units primarily intended for industrial or similar use and to be fixed to a support to provide electrical and mechanical connection between copper conductors. It applies to terminal blocks intended to connect round copper conductors, with or without special preparation, having a cross-section between 0,2 mm² and 300 mm² (AWG 24/600 kcmil), intended to be used in circuits of a rated voltage not exceeding 1 000 V a.c. up to 1 000 Hz or 1 500 V d.c.

NOTE AWG is the abbreviation of “American Wire Gage” (Gage (US) = Gauge (UK))

kcmil = 1 000 cmil;

1 cmil = 1 circular mil = surface of a circle having a diameter of 1 mil

1 mil = 1/1 000 inch

This standard may be used as a guide for

- terminal blocks requiring the fixing of special devices to the conductors, for example quick connect terminations or wrapped connections, etc.;
- terminal blocks providing direct contact to the conductors by means of edges or points penetrating the insulation, for example insulation displacement connections, etc.;
- special types of terminal blocks, for example with diodes or varistors or similar component holders, etc.

Where applicable in this standard, the term “clamping unit” has been used instead of the term “terminal”. This is taken into account in case of reference to IEC 60947-1.

1.2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60695-11-5:2004, *Fire hazard testing – Part 11-5: Test flames – Needle-flame test method – Apparatus, confirmatory test arrangement and guidance*

IEC 60947-1:2007, *Low-voltage switchgear and controlgear – Part 1: General rules*

ISO 4046-4:2002, *Paper, board, pulp and related terms – Vocabulary – Part 4: Paper and board grades and converted products*