

© Copyright SEK. Reproduction in any form without permission is prohibited.

Rules for the determination of uncertainties in the measurement of the losses on power transformers and reactor

(CENELEC Technical Report 50462:2008)

ISSN 1651-1417

ICS 29.180

Upplysningar om **sakinnehållet** i rapporten lämnas av
SEK Svensk Elstandard.
Postadress: SEK, Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00. Telefax: 08 - 444 14 30
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Rules for the determination of uncertainties in the measurement
of the losses on power transformers and reactors**

This Technical Report was approved by CENELEC on 2008-03-07.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

Foreword

This Technical Report was prepared by the Technical Committee CENELEC TC 14, Power transformers.

The text of the draft was submitted to vote in accordance with the Internal Regulations, Part 2, Subclause 11.4.3.3 (simple majority) and was approved by CENELEC as CLC/TR 50462 on 2008-03-07.

Contents

Introduction.....	5
1 Scope.....	6
2 Normative references	6
3 Definitions	6
4 Symbols	6
4.1 General symbols	6
4.2 Symbols for uncertainty.....	7
5 Power measurement, systematic deviation and uncertainty	8
6 Procedures for no-load loss.....	8
6.1 General.....	8
6.2 Model function for no-load losses at reference conditions.....	9
6.3 Uncertainty budget	10
7 Procedures for load loss.....	11
7.1 General.....	11
7.2 Model function for load loss at reference conditions	11
7.3 Uncertainty budget for measured power P_2 referred to rated current.....	12
7.4 Uncertainty budget for reported load loss	14
8 Three-phase calculations.....	14
8.1 Power.....	14
8.2 Reference voltage (current).....	15
9 Reporting	15
9.1 Uncertainty.....	15
9.2 Traceability	15
10 Estimation of corrections and uncertainty contributions	15
10.1 Ratio error of instrument transformers	15
10.2 Phase displacement of instrument transformers	17
10.3 Power meter.....	21
10.4 Voltage measurement in no-load loss	22
10.5 Ampere meter in load loss measurement.....	22
10.6 Correction to sinusoidal waveform.....	23
10.7 Winding temperature θ at load loss test.....	23
10.8 Winding resistance	24
Annex A (informative) Example of load loss uncertainty evaluation for a large power transformer	26
A.1 Introduction	26
A.2 Transformer rating.....	26
A.3 Measuring method and instrumentation used.....	26
A.4 Model of the measurand (see 7.2)	27
A.5 Results of the measurements	27
A.6 Uncertainty of load loss	28
A.7 Estimates of the single contributions to the uncertainty	30
Annex B (informative) Example of load loss uncertainty evaluation for a distribution transformer	34
B.1 Introduction	34
B.2 Transformer rating.....	34
B.3 Measuring instrumentation	34

B.4	Model of the measurand (see 7.2)	34
B.5	Results of the measurements	35
B.6	Uncertainty of load loss	36
B.7	Estimate of the single contributions to the uncertainty formation.....	37
Annex C (informative)	General rules for the uncertainty estimate	40
C.1	The basic concepts	40
C.2	Measurements, estimates and uncertainties	40
C.3	Evaluation of the input quantity uncertainties.....	41
C.4	Evaluation and expression of the expanded uncertainty	44
Annex D (informative)	Sensitivity coefficients for uncertainty contributions due to phase displacement correction of measurements at low power factor	45
D.1	Introduction	45
D.2	Sensitivity factors	46
Annex E (informative)	Model function for load loss temperature correction	51
E.1	General	51
E.2	Model function.....	51
E.3	Sensitivity coefficients	52
E.4	Estimation of temperature during load loss test	53
E.5	Simplified analysis.....	53
Annex F (informative)	Measurement of winding resistance	55
F.1	Description of the measurement	55
F.2	Inductive voltage drop	56
Bibliography	58
Figures		
Figure D.1	– Sensitivity coefficient for uncertainty in power, current and voltage.....	48
Figure F.1	– Equivalent circuit	55
Tables		
Table 1	– No-load loss uncertainty, general case	10
Table 2	– No-load loss uncertainty without correction for phase displacement	11
Table 3	– Uncertainty in the general case	13
Table 4	– Uncertainty without correction for phase displacement	13
Table 5	– Standard and expanded uncertainty for load loss	14
Table 6	– Procedures for uncertainty analysis.....	18
Table A.1	– Uncertainty contribution	29
Table A.2	– Calibration of voltage and current transformers ratio error.....	30
Table A.3	31
Table A.4	– Calibration of voltage and current transformer phase displacement.....	32
Table B.1	35
Table B.2	– Uncertainty contribution	36
Table B.3	38
Table B.4	38
Table C.1	– Combined uncertainties for uncorrelated quantities	43
Table E.1	53

Introduction

Although the efficiency of a power transformer is very high, the losses (no load and load losses) are object of guaranty and penalty in the majority of the contracts. As a matter of fact, considering the long power transformer life (20 years and more) the cost of the losses play an important role in the evaluation of the total (service) costs and therefore in the investments involved.

A further reason that justifies the attention paid to the losses is that from the generation to the final user, the energy is passing through a number of transformers: step up transformers of generation power stations, interconnecting units for transmission systems, distribution transformers for primary systems (from 100 kV to 400 kV), medium voltage to low voltage transformers in small distribution substations (from 10 kV to 20 kV feeders).

The sum of the losses accrued in the transformer chains may be significant and therefore of importance in nationwide efforts to save energy. A large number of European Countries have instituted measures to conserve energy where losses in electric transmission are an important part.

In power transformers the direct measurement of the efficiency is not recommended because of the uncertainty of this method.

The indirect method based on the measurement of the losses is largely preferred even if the conditions in which such losses are measured differ a little from those that occur in operation.

EN ISO/IEC 17025 requires that the result of any measurement shall be qualified with the evaluation of its uncertainty. A further requirement is that known corrections shall have been applied before evaluation of uncertainty.

This document deals with the measurement of the losses that from a measuring point of view consist of the estimate of a measurand and the evaluation of the uncertainty that affects the estimate itself.

It is well known that when a test result is expressed as numerical quantity it is not an exact number but suffers from uncertainty.

The uncertainty range depends on the quality of the test installation and measuring system, on the skill of the staff and on the intrinsic measurement difficulties presented by the test objects.

The submitted test results is to be considered the most correct estimate and therefore this value has to be accepted as it stands.

The uncertainty shall not be involved in the judgment of compliance for guarantees, tolerances and penalties thresholds.

Guaranty and penalty calculations should refer to the estimated values without consideration of the measurement uncertainties.

1 Scope

This Technical Report illustrates the procedures and criteria to be applied to evaluate the uncertainty affecting the measurements of no load and load losses during the routine tests on power transformers.

Even if the attention is especially paid to the transformers, the document can be also used for the measurements of reactor losses, when applicable.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 60076 series, Power transformers (IEC 60076 series)

EN 60076-1:1996, Power transformers – Part 1: General (IEC 60076-1:1993, mod.)