

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Nät med hög driftsäkerhet – Del 6: Distributed Redundancy Protocol (DRP)

*Industrial communication networks –
High availability automation networks –
Part 6: Distributed Redundancy Protocol (DRP)*

Som svensk standard gäller europastandarden EN 62439-6:2010. Den svenska standarden innehåller den officiella engelska språkversionen av EN 62439-6:2010.

Nationellt förord

Europastandarden EN 62439-6:2010

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 62439-6, First edition, 2010 - Industrial communication networks - High availability automation networks - Part 6: Distributed Redundancy Protocol (DRP)**

utarbetad inom International Electrotechnical Commission, IEC.

Denna standard, och de andra delarna i serien SS-EN 62439, ersätter SS-EN 62439, utg 1, 2009.

Tidigare fastställd svensk standard SS-EN 62439 utg 1, 2009, gäller ej fr o m 2013-03-01.

ICS 25.040; 35.040

Denna standard är fastställd av SEK Svensk Elstandard, som också kan lämna upplysningar om **sakinnehållet** i standarden.
Postadress: SEK, Box 1284, 164 29 KISTA
Telefon: 08 - 444 14 00. Telefax: 08 - 444 14 30
E-post: sek@elstandard.se. Internet: www.elstandard.se

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Industrial communication networks -
High availability automation networks -
Part 6: Distributed Redundancy Protocol (DRP)
(IEC 62439-6:2010)**

Réseaux de communication industrielle -
Réseaux d'automatisme à haute
disponibilité -
Partie 6 : Protocole de redondance
distribuée (DRP)
(CEI 62439-6:2010)

Industrielle Kommunikationsnetze -
Hochverfügbare Automatisierungsnetze -
Teil 6: Protokoll für verteilte Redundanz
(DRP)
(IEC 62439-6:2010)

This European Standard was approved by CENELEC on 2010-03-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 65C/583/FDIS, future edition 1 of IEC 62439-6, prepared by SC 65C, Industrial networks, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 62439-6 on 2010-03-01.

This EN 62439-6 together with EN 62439-1, EN 62439-2, EN 62439-3, EN 62439-4 and EN 62439-5 supersedes EN 62439:2008.

EN 62439-6:2010 includes the following significant technical changes with respect to EN 62439:2008:

- adding a calculation method for RSTP (rapid spanning tree protocol, IEEE 802.1Q),
- adding two new redundancy protocols: HSR (High-availability Seamless Redundancy) and DRP (Distributed Redundancy Protocol),
- moving former Clauses 1 to 4 (introduction, definitions, general aspects) and the Annexes (taxonomy, availability calculation) to EN 62439-1, which serves now as a base for the other documents,
- moving Clause 5 (MRP) to EN 62439-2 with minor editorial changes,
- moving Clause 6 (PRP) was to EN 62439-3 with minor editorial changes,
- moving Clause 7 (CRP) was to EN 62439-4 with minor editorial changes, and
- moving Clause 8 (BRP) was to EN 62439-5 with minor editorial changes,
- adding a method to calculate the maximum recovery time of RSTP in a restricted configuration (ring) to EN 62439-1 as Clause 8,
- adding specifications of the HSR (High-availability Seamless Redundancy) protocol, which shares the principles of PRP to EN 62439-3 as Clause 5, and
- introducing the DRP protocol as EN 62439-6.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented at national level by publication of an identical national standard or by endorsement | (dop) | 2010-12-01 |
| – latest date by which the national standards conflicting with the EN have to be withdrawn | (dow) | 2013-03-01 |

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 62439-6:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

IEC 62439-2	NOTE	Harmonized as EN 62439-2.
IEC 62439-3	NOTE	Harmonized as EN 62439-3.
IEC 62439-4	NOTE	Harmonized as EN 62439-4.
IEC 62439-5	NOTE	Harmonized as EN 62439-5.

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60050-191	-	International Electrotechnical Vocabulary (IEV) - Chapter 191: Dependability and quality of service	-	-
IEC 61158	Series	Fieldbus standard for use in industrial control systems	EN 61158	Series
IEC 61588	2009	Precision clock synchronization protocol for networked measurement and control systems	-	-
IEC 62439-1	2010	Industrial communication networks - High availability automation networks - Part 1: General concepts and calculation methods	EN 62439-1	2010
ISO/IEC/TR 8802-1	-	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 1: Overview of Local Area Network Standards	-	-
ISO/IEC 8802-3	2000	Information technology - Telecommunications - and information exchange between systems - Local and metropolitan area networks - Specific requirements - Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications	-	-
IEEE 802.1D	2004	IEEE Standard for Local and Metropolitan Area Networks - Media Access Control (MAC) Bridges	-	-
IEEE 802.1Q	-	IEEE Standard for Local and Metropolitan Area Networks - Virtual Bridged Local Area Networks	-	-

CONTENTS

INTRODUCTION.....	7
1 Scope.....	8
2 Normative references	8
3 Terms, definitions, abbreviations, acronyms, and conventions	8
3.1 Terms and definitions	8
3.2 Abbreviations and acronyms.....	9
3.3 Conventions	9
4 Overview	9
4.1 Principles	9
4.2 Ring ports	10
4.3 DRP switch node.....	10
4.4 Single ring topology redundancy.....	11
4.5 Double ring topology redundancy	11
4.6 Configuration.....	12
4.6.1 Overview	12
4.6.2 Manufacturer configuration	12
4.6.3 Communication configuration.....	12
4.6.4 Application configuration	13
4.7 Start up	13
5 DRP communications	13
5.1 Overview	13
5.2 Communication procedure	15
5.3 Fault detection and recovery	18
5.3.1 General	18
5.3.2 Handling in a single ring network	19
5.3.3 Handling in a double ring network.....	20
5.4 Repairing the inter-switch link fault.....	21
5.5 Repairing time synchronization fault.....	21
5.6 Inserting a repaired switch node.....	22
5.7 Inserting a new switch node	23
6 DRP class specification	23
7 DRP attributes	24
8 DRP services	27
8.1 Read	27
8.2 Write	30
9 DRP protocol specification.....	32
9.1 Basic types encoding	32
9.2 ErrorDescription encoding	32
9.3 Encoding of DRP Class	33
9.4 PDU description	34
9.4.1 Encoding of DRP DLPDU	34
9.4.2 Encoding of DLSDU.....	35
9.4.3 Encoding of VLAN	35
9.4.4 Ethertype.....	35

9.4.5	Encoding of DRP PDU	35
9.4.6	Encoding of DRP_DATA	36
9.4.7	Encoding of Read Service	40
9.4.8	Encoding of Write Service primitives.....	42
9.5	Protocol machine.....	44
9.5.1	Switch node states description	44
9.5.2	Protocol State Machine description.....	44
9.5.3	State transitions	45
9.5.4	Function descriptions.....	52
	Bibliography.....	64
Figure 1	– DRP communication model	10
Figure 2	– Single ring topology redundancy	11
Figure 3	– Double ring topology redundancy	12
Figure 4	– DRP communication procedure	14
Figure 5	– Inserting a new switch node into the DRP system	14
Figure 6	– Fault detection and recovery	15
Figure 7	– Fault detection and recovery of single ring topology redundancy.....	19
Figure 8	– Single inter-switch link fault detection and recovery of double ring topology redundancy.....	20
Figure 9	– Double inter-switch link fault detection and recovery of double ring topology redundancy.....	21
Figure 10	– Inserting a repaired switch node.....	22
Figure 11	– DRP protocol state machine	45
Table 1	– Relationship between required recovery time and the TargetTimeSyncClass.....	22
Table 2	– Parameters of Read service	27
Table 3	– Parameters of Write service	30
Table 4	– Error Type definition.....	32
Table 5	– Error Code definition	33
Table 6	– Definition of DRP Class	33
Table 7	– DRP OUI	34
Table 8	– DRP MulticastMACAddress	35
Table 9	– Encoding of DLSDU	35
Table 10	– Encoding of DRP PDU.....	35
Table 11	– DRP_Type definition	35
Table 12	– Encoding of RingCheck frame	36
Table 13	– Encoding of DeviceAnnunciation frame.....	37
Table 14	– Encoding of RingChange frame	39
Table 15	– Encoding of LinkCheck frame	39
Table 16	– Encoding of LinkAlarm frame.....	40
Table 17	– Encoding of LinkChange frame.....	40
Table 18	– Encoding of Read Request	41
Table 19	– Encoding of Read Service Positive Response	41
Table 20	– Encoding of Read Service Negative Response	42

Table 21 – Encoding of Write Request	43
Table 22 – Encoding of Write Service Positive Response.....	43
Table 23 – Encoding of Write Service Negative Response	43
Table 24 – DRP state transitions.....	46
Table 25 – SetRingPortState() descriptions	52
Table 26 – LoadRingPortState() descriptions	52
Table 27 – WriteSucceed() descriptions	52
Table 28 – SynchronizationFinished() descriptions	53
Table 29 – ActivePortLinkState() descriptions	53
Table 30 – StandbyPortLinkState() descriptions.....	53
Table 31 – ConfigureInfo() descriptions	53
Table 32 – DRPSendTimer() descriptions	54
Table 33 – SendRingChange() descriptions	54
Table 34 – ForwardingRingCheck() descriptions	54
Table 35 – AnnunciationBlockingPort() descriptions.....	54
Table 36 – LocalDRPSequenceIDSmaller() descriptions	55
Table 37 – RecvAnnunciationWithinTimeLimit() descriptions.....	55
Table 38 – RecvLinkCheckWithinTimeLimit() descriptions.....	55
Table 39 – NoLocalLinkFault() descriptions	55
Table 40 – RecvLinkAlarm() descriptions	56
Table 41 – Clear_FDB() descriptions	56
Table 42 – ChangeRingState() descriptions	56
Table 43 – BlockingPortSelect() descriptions	56
Table 44 – SendLinkChange() descriptions.....	57
Table 45 – DRPSequenceIDCompare() descriptions	57
Table 46 – ChangePortState() descriptions.....	57
Table 47 – ChangeDoublePortState() descriptions	57
Table 48 – LocalSendRingCheck() descriptions	58
Table 49 – DRPKeyParaConfigure() descriptions	58
Table 50 – CheckMACAddress() descriptions	58
Table 51 – SetDRPKeyPara() descriptions.....	58
Table 52 – SendDeviceAnnunciation() descriptions.....	59
Table 53 – FaultRecvRingCheck() descriptions.....	59
Table 54 – RecordDeviceState() descriptions	59
Table 55 – DrpRecvMsg() descriptions	59
Table 56 – SendLinkAlarm() descriptions.....	60
Table 57 – TimeUnsynchronization() descriptions	60
Table 58 – PassiveMasterState() descriptions	60
Table 59 – SearchDeviceState() descriptions.....	60
Table A.1 – An example of parameters setting for DRP Class	62
Table A.2 – Parameters for calculation of recovery time.....	63

INTRODUCTION

The IEC 62439 series specifies relevant principles for high availability networks that meet the requirements for industrial automation networks.

In the fault-free state of the network, the protocols of the IEC 62439 series provide ISO/IEC 8802-3 (IEEE 802.3) compatible, reliable data communication, and preserve determinism of real-time data communication. In cases of fault, removal, and insertion of a component, they provide deterministic recovery times.

These protocols retain fully the typical Ethernet communication capabilities as used in the office world, so that the software involved remains applicable.

The market is in need of several network solutions, each with different performance characteristics and functional capabilities, matching diverse application requirements. These solutions support different redundancy topologies and mechanisms which are introduced in IEC 62439-1 and specified in the other Parts of the IEC 62439 series. IEC 62439-1 also distinguishes between the different solutions, giving guidance to the user.

The IEC 62439 series follows the general structure and terms of IEC 61158 series.

The International Electrotechnical Commission (IEC) draws attention to the fact that it is claimed that compliance with this document may involve the use of a patent concerning about the communication procedure and fault detection and recovery for DRP given in 5.2 and 5.3.

IEC takes no position concerning the evidence, validity and scope of this patent right.

The holder of this patent right has assured the IEC that he/she is willing to negotiate licences either free of charge or under reasonable and non-discriminatory terms and conditions with applicants throughout the world. In this respect, the statement of the holder of this patent right is registered with IEC. Information may be obtained from:

SUPCON Group Co., Ltd & Zhejiang University
Hangzhou
China

Beijing Kyland Technology Co. LTD
No 95 Building
Southeast Corner of Xisanqi Bridge
Haidian
Beijing
China

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights other than those identified above. IEC shall not be held responsible for identifying any or all such patent rights.

ISO (www.iso.org/patents) and IEC (http://www.iec.ch/tctools/patent_decl.htm) maintain on-line data bases of patents relevant to their standards. Users are encouraged to consult the data bases for the most up to date information concerning patents.

INDUSTRIAL COMMUNICATION NETWORKS – HIGH AVAILABILITY AUTOMATION NETWORKS –

Part 6: Distributed Redundancy Protocol (DRP)

1 Scope

The IEC 62439 series is applicable to high-availability automation networks based on the ISO/IEC 8802-3 (IEEE 802.3) (Ethernet) technology.

This part of the IEC 62439 series specifies a recovery protocol based on a ring topology, designed to react deterministically on a single failure of an inter-switch link or switch in the network. Each switch has equal management role in the network. Double rings are supported.

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60050-191, *International Electrotechnical Vocabulary – Chapter 191: Dependability and quality of service*

IEC 61158 (all parts), *Industrial communication networks – Fieldbus specifications*

IEC 61588:2009, *Precision clock synchronization protocol for networked measurement and control systems* (IEEE 1588)

IEC 62439-1:2010, *Industrial communication networks – High availability automation networks – Part 1: General concepts and calculation methods*

ISO/IEC/TR 8802-1, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 1: Overview of Local Area Network Standards Technologies de* (IEEE 802.1)

ISO/IEC 8802-3:2000, *Information technology – Telecommunications and information exchange between systems – Local and metropolitan area networks – Specific requirements – Part 3: Carrier sense multiple access with collision detection (CSMA/CD) access method and physical layer specifications*

IEEE 802.1D:2004, *IEEE standard for local Local and metropolitan area networks Media Access Control (MAC) Bridges*

IEEE 802.1Q, *IEEE standards for local and metropolitan area network. Virtual bridged local area networks*

