

© Copyright SEK. Reproduction in any form without permission is prohibited.

Industriell processtyrning – Reglerventiler – Del 8-3: Buller – Prediktering av aerodynamiskt buller

Industrial process control valves –

Part 8-3: Noise considerations –

Control valve aerodynamic noise prediction method

Som svensk standard gäller europastandarden EN 60534-8-3:2011. Den svenska standarden innehåller den officiella engelska språkversionen av EN 60534-8-3:2011.

Nationellt förord

Europastandarden EN 60534-8-3:2011

består av:

- **europastandardens ikraftsättningsdokument**, utarbetat inom CENELEC
- **IEC 60534-8-3, Third edition, 2010 - Industrial process control valves - Part 8-3: Noise considerations - Control valve aerodynamic noise prediction method**

utarbetad inom International Electrotechnical Commission, IEC.

Tidigare fastställd svensk standard SS-EN 60534-8-3, utgåva 2, 2001, gäller ej fr o m 2014-01-01.

Standarder underlättar utvecklingen och höjer elsäkerheten

Det finns många fördelar med att ha gemensamma tekniska regler för bl a säkerhet, prestanda, dokumentation, utförande och skötsel av elprodukter, elanläggningar och metoder. Genom att utforma sådana standarder blir säkerhetskraven tydliga och utvecklingskostnaderna rimliga samtidigt som marknadens acceptans för produkten eller tjänsten ökar.

Många standarder inom elområdet beskriver tekniska lösningar och metoder som åstadkommer den elsäkerhet som föreskrivs av svenska myndigheter och av EU.

SEK är Sveriges röst i standardiseringsarbetet inom elområdet

SEK Svensk Elstandard svarar för standardiseringen inom elområdet i Sverige och samordnar svensk medverkan i internationell och europeisk standardisering. SEK är en ideell organisation med frivilligt deltagande från svenska myndigheter, företag och organisationer som vill medverka till och påverka utformningen av tekniska regler inom elektrotekniken.

SEK samordnar svenska intressenters medverkan i SEKs tekniska kommittéer och stödjer svenska experters medverkan i internationella och europeiska projekt.

Stora delar av arbetet sker internationellt

Utformningen av standarder sker i allt väsentligt i internationellt och europeiskt samarbete. SEK är svensk nationalkommitté av International Electrotechnical Commission (IEC) och Comité Européen de Normalisation Electrotechnique (CENELEC).

Standardiseringsarbetet inom SEK är organiserat i referensgrupper bestående av ett antal tekniska kommittéer som speglar hur arbetet inom IEC och CENELEC är organiserat.

Arbetet i de tekniska kommittéerna är öppet för alla svenska organisationer, företag, institutioner, myndigheter och statliga verk. Den årliga avgiften för deltagandet och intäkter från försäljning finansierar SEKs standardiseringsverksamhet och medlemsavgift till IEC och CENELEC.

Var med och påverka!

Den som deltar i SEKs tekniska kommittéarbete har möjlighet att påverka framtida standarder och får tidig tillgång till information och dokumentation om utvecklingen inom sitt teknikområde. Arbetet och kontakterna med kollegor, kunder och konkurrenter kan gynnsamt påverka enskilda företags affärsutveckling och bidrar till deltagarnas egen kompetensutveckling.

Du som vill dra nytta av dessa möjligheter är välkommen att kontakta SEKs kansli för mer information.

SEK Svensk Elstandard

Box 1284
164 29 Kista
Tel 08-444 14 00
www.elstandard.se

English version

**Industrial-process control valves -
Part 8-3: Noise considerations -
Control valve aerodynamic noise prediction method
(IEC 60534-8-3:2010)**

Vannes de régulation des processus
industriels -
Partie 8-3: Considérations sur le bruit -
Méthode de prédiction du bruit
aérodynamique des vannes de régulation
(CEI 60534-8-3:2010)

Stellventile für die Prozessregelung -
Teil 8-3: Geräuschbetrachtungen -
Berechnungsverfahren zur Vorhersage
der aerodynamischen Geräusche von
Stellventilen
(IEC 60534-8-3:2010)

This European Standard was approved by CENELEC on 2011-01-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the Central Secretariat or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the Central Secretariat has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Slovakia, Slovenia, Spain, Sweden, Switzerland and the United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Management Centre: Avenue Marnix 17, B - 1000 Brussels

Foreword

The text of document 65B/765/FDIS, future edition 3 of IEC 60534-8-3, prepared by IEC/SC 65B, Devices & process analysis, of IEC TC 65, Industrial-process measurement, control and automation, was submitted to the IEC-CENELEC parallel vote and was approved by CENELEC as EN 60534-8-3 on 2011-01-01.

This European Standard supersedes EN 60534-8-3:2000.

The significant technical changes with respect to EN 60534-8-3:2000 are as follows:

- predicting noise as a function of frequency;
- using laboratory data to determine the acoustical efficiency factor.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CEN and CENELEC shall not be held responsible for identifying any or all such patent rights.

The following dates were fixed:

- | | | |
|--|-------|------------|
| – latest date by which the EN has to be implemented
at national level by publication of an identical
national standard or by endorsement | (dop) | 2011-10-01 |
| – latest date by which the national standards conflicting
with the EN have to be withdrawn | (dow) | 2014-01-01 |

Annex ZA has been added by CENELEC.

Endorsement notice

The text of the International Standard IEC 60534-8-3:2010 was approved by CENELEC as a European Standard without any modification.

In the official version, for Bibliography, the following notes have to be added for the standards indicated:

- | | | |
|-------------------|------|-----------------------------|
| [1] IEC 60534-2-1 | NOTE | Harmonized as EN 60534-2-1. |
| [2] IEC 60534-8-1 | NOTE | Harmonized as EN 60534-8-1. |
-

Annex ZA (normative)

Normative references to international publications with their corresponding European publications

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NOTE When an international publication has been modified by common modifications, indicated by (mod), the relevant EN/HD applies.

<u>Publication</u>	<u>Year</u>	<u>Title</u>	<u>EN/HD</u>	<u>Year</u>
IEC 60534	Series	Industrial-process control valves	EN 60534	Series
IEC 60534-1	-	Industrial-process control valves - Part 1: Control valve terminology and general considerations	EN 60534-1	-

CONTENTS

INTRODUCTION	6
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 Symbols	9
5 Valves with standard trim	12
5.1 Pressures and pressure ratios.....	12
5.2 Regime definition	13
5.3 Preliminary calculations	14
5.3.1 Valve style modifier F_d	14
5.3.2 Jet diameter D_j	14
5.3.3 Inlet fluid density ρ_1	14
5.4 Internal noise calculations.....	15
5.4.1 Calculations common to all regimes.....	15
5.4.2 Regime dependent calculations	16
5.4.3 Downstream calculations.....	18
5.4.4 Valve internal sound pressure calculation at pipe wall	19
5.5 Pipe transmission loss calculation.....	20
5.6 External sound pressure calculation.....	21
5.7 Calculation flow chart	22
6 Valves with special trim design	22
6.1 General	22
6.2 Single stage, multiple flow passage trim.....	22
6.3 Single flow path, multistage pressure reduction trim (two or more throttling steps)	23
6.4 Multipath, multistage trim (two or more passages and two or more stages)	25
7 Valves with higher outlet Mach numbers	27
7.1 General	27
7.2 Calculation procedure	27
8 Valves with experimentally determined acoustical efficiency factors	28
9 Combination of noise produced by a control valve with downstream installed two or more fixed area stages.....	29
Annex A (informative) Calculation examples.....	31
Bibliography	46
Figure 1 – Single stage, multiple flow passage trim	23
Figure 2 – Single flow path, multistage pressure reduction trim	24
Figure 3 – Multipath, multistage trim (two or more passages and two or more stages).....	26
Figure 4 – Control valve with downstream installed two fixed area stages.....	30
Table 1 – Numerical constants N	15
Table 2 – Typical values of valve style modifier F_d (full size trim)	15
Table 3 – Overview of regime dependent equations	17

Table 4 – Typical values of A_{η} and St_p	18
Table 5 – Indexed frequency bands	19
Table 6 – Frequency factors $G_x(f)$ and $G_y(f)$	21
Table 7 – “A” weighting factor at frequency f_i	22

INTRODUCTION

The mechanical stream power as well as acoustical efficiency factors are calculated for various flow regimes. These acoustical efficiency factors give the proportion of the mechanical stream power which is converted into internal sound power.

This method also provides for the calculation of the internal sound pressure and the peak frequency for this sound pressure, which is of special importance in the calculation of the pipe transmission loss.

At present, a common requirement by valve users is the knowledge of the sound pressure level outside the pipe, typically 1 m downstream of the valve or expander and 1 m from the pipe wall. This standard offers a method to establish this value.

The equations in this standard make use of the valve sizing factors as used in IEC 60534-1 and IEC 60534-2-1.

In the usual control valve, little noise travels through the wall of the valve. The noise of interest is only that which travels downstream of the valve and inside of the pipe and then escapes through the wall of the pipe to be measured typically at 1 m downstream of the valve body and 1 m away from the outer pipe wall.

Secondary noise sources may be created where the gas exits the valve outlet at higher Mach numbers. This method allows for the estimation of these additional sound levels which can then be added logarithmically to the sound levels created within the valve.

Although this prediction method cannot guarantee actual results in the field, it yields calculated predictions within 5 dB(A) for the majority of noise data from tests under laboratory conditions (see IEC 60534-8-1). The current edition has increased the level of confidence of the calculation. In some cases the results of the previous editions were more conservative.

The bulk of the test data used to validate the method was generated using air at moderate pressures and temperatures. However, it is believed that the method is generally applicable to other gases and vapours and at higher pressures. Uncertainties become greater as the fluid behaves less perfectly for extreme temperatures and for downstream pressures far different from atmospheric, or near the critical point. The equations include terms which account for fluid density and the ratio of specific heat.

NOTE Laboratory air tests conducted with up to 1 830 kPa (18,3 bar) upstream pressure and up to 1 600 kPa (16,0 bar) downstream pressure and steam tests up to 225 °C showed good agreement with the calculated values.

A rigorous analysis of the transmission loss equations is beyond the scope of this standard. The method considers the interaction between the sound waves existing in the pipe fluid and the first coincidence frequency in the pipe wall. In addition, the wide tolerances in pipe wall thickness allowed in commercial pipe severely limit the value of the very complicated mathematical approach required for a rigorous analysis. Therefore, a simplified method is used.

Examples of calculations are given in Annex A.

This method is based on the IEC standards listed in Clause 2 and the references given in the Bibliography.

INDUSTRIAL-PROCESS CONTROL VALVES –

Part 8-3: Noise considerations – Control valve aerodynamic noise prediction method

1 Scope

This part of IEC 60534 establishes a theoretical method to predict the external sound-pressure level generated in a control valve and within adjacent pipe expanders by the flow of compressible fluids.

This method considers only single-phase dry gases and vapours and is based on the perfect gas laws.

This standard addresses only the noise generated by aerodynamic processes in valves and in the connected piping. It does not consider any noise generated by reflections from external surfaces or internally by pipe fittings, mechanical vibrations, unstable flow patterns and other unpredictable behaviour.

It is assumed that the downstream piping is straight for a length of at least 2 m from the point where the noise measurement is made.

This method is valid only for steel and steel alloy pipes (see Equations (21) and (23) in 5.5).

The method is applicable to the following single-stage valves: globe (straight pattern and angle pattern), butterfly, rotary plug (eccentric, spherical), ball, and valves with cage trims. Specifically excluded are the full bore ball valves where the product $F_p C$ exceeds 50 % of the rated flow coefficient.

For limitations on special low noise trims not covered by this standard, see Clause 8. When the Mach number in the valve outlet exceeds 0,3 for standard trim or 0,2 for low noise trim, the procedure in Clause 7 is used

The Mach number limits in this standard are as follows:

Mach number location	Mach number limit		
	Clause 5 Standard trim	Clause 6 Noise-reducing trim	Clause 7 High Mach number applications
Freely expanded jet M_j	No limit	No limit	No limit
Valve outlet M_o	0,3	0,2	1,0
Downstream reducer inlet M_r	Not applicable	Not applicable	1,0
Downstream pipe M_2	0,3	0,2	0,8

2 Normative references

The following referenced documents are indispensable for the application of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60534 (all parts), *Industrial-process control valves*

IEC 60534-1, *Industrial-process control valves – Part 1: Control valve terminology and general considerations*